

Re: Correction to EC Measures on Lots 9 and 10

Tuesday, March 24, 2020 9:36 AM

| | |
|----------------|---|
| Subject | Re: Correction to EC Measures on Lots 9 and 10 |
| From | Camille Leung |
| To | Robert Pellegrine; Amy Ow |
| Sent | Tuesday, March 17, 2020 5:55 PM |

Please work with Adolfo and Scott.

From: Robert Pellegrine <robertpellegrine@yahoo.com>

Sent: Tuesday, March 17, 2020 5:51 PM

To: Camille Leung <cleung@smcgov.org>

Subject: Re: Correction to EC Measures on Lots 9 and 10

CAUTION: This email originated from outside of San Mateo County. Unless you recognize the sender's email address and know the content is safe, do not click links, open attachments or reply.

Ok thanks for the response

I talked with Roland (BKF)

He says everything is all-inclusive and says it goes way back to someone named Diane who requested doing it the way it was done

I hope this info rings some old bells

I am going to get Roland to e mail you what he has

Thanks Bob Pellegrine

Nexgen

Sent from my iPhone

On Mar 17, 2020, at 5:33 PM, Camille Leung <cleung@smcgov.org> wrote:

Hi Bob,

I think you may have gotten an encroachment permit from DPW for the driveways, but I think you need to get a separate one for the drainage work. Please work with Adolfo and Scott (both copied here).

I sent an email to Jack re: what we need for Lot 11. I'll re-send it to you.

Thanks

From: Robert Pellegrine <robertpellegrine@yahoo.com>

Sent: Tuesday, March 17, 2020 1:03 PM

To: Camille Leung <cleung@smcgov.org>

Subject: Re: Correction to EC Measures on Lots 9 and 10

CAUTION: This email originated from outside of San Mateo County. Unless you recognize the sender's email address and know the content is safe, do not click links, open attachments or reply.

Hi Camille

I just talked with Scott from county street inspection and he tells me we do not have an encroachment permit for the storm drains and I told him yes we have all permits and they were all

inclusive with our permit package for lots 9 & 10 could you please forward to him a copy of permit for storm drains for Cobblehill as we are ready to start storm drain install very soon and will need some inspections

And how are the permits for lot 11 coming

End of March is nearing

Thanks

Bob Pellgrine

Nexgen

650-546-2214

Sent from my iPhone

On Oct 1, 2019, at 1:06 PM, Camille Leung <cleung@smcgov.org> wrote:

Hi Bob and Melissa,

After you complete the below correction for Lots 9 and 10, please send pictures to Jessie and Kristen. They will let you know whether they need to inspect again.

There is one outstanding item that should be addressed prior to grading:

- Lots 9 and 10: Silt fence along the west and east sides of Lot 9 and the north and the east sides of Lot 10 has been installed to more accurately reflect the Civil Plan's limit of grading. However, none of the silt fence is trenched or keyed in, as per the specifications for silt fence installation provided in the California Stormwater BMP Handbook (see attached SE-1). SWCA recommends the contractor keys in the silt fence as required by the SWPPP (see attached specification) prior to the start of construction.

Camille Leung, Senior Planner
Planning & Building Department
San Mateo County
455 County Center, 2nd Floor
Redwood City, CA 94063
Phone - 650-363-1826
Fax – 650-363-4849